



PUNEMETROPOLIS

पुणे महानगर प्रदेश विकास प्राधिकरण, पुणे  
Pune metropolitan Regional Development Authority, Pune

अग्निशमन विभाग, आकुर्डी रेल्वे स्टेशन जवळ, नवीन प्रशासकीय इमारत,  
०४ था मजला, अ-विंग, आकुर्डी-४११०३५

ई-मेल- [fireofficer.pmrda@gmail.com](mailto:fireofficer.pmrda@gmail.com), दूरध्वनी क्र:- २७६५९८५५-०२०



FIRE/PMRDA/07/22/2024

Date: 19/08/2024

TO,

M/s. Indoscots Foundation School,  
Gat No. 1211+1213 to 1216, 1218,  
Village-Wagholi,  
Tal-Haveli, Dist-Pune.

**Sub:- Fire Safety Compliance for your Educational Building**

Ref: i)"Final NOC" issued by this office vide no. FFH/159/2023-24 Dated.  
01.10.2018


ii)Your Letter No. 8023/2024-25 Dated- 12.08.2024

Dear sir,

With reference to your letter under reference (ii) above this is to inform you that, the M/s. Indoscots Foundation School, on Gat No. 1211+1213 to 1216, 1218, Village-Wagholi, Tal-Haveli, Dist-Pune. have complied with the fire prevention & fire safety requirement in accordance with NBC-2016 for B+G+07 Floor Education Building. Ref. (i) for B+G+07 Floor Bldg., However at present construction is done up to B+G+07 Bldg. now proposed occupancy for Education is up to B+G+07 Floor. have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the officers concerned of Fire Services on 13915/2023, in the presence of M/s. Manoj Group (MFS-LA/RF-616, RD-585) and that the building is fit for occupancy upto classes XII with the 06.07.2025 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended.

1. The scope of this letter is restricted to fire protection arrangements only. This letter should not be treated/ presumed as an approval for civil / architectural drawings.
2. The area calculation statements TDR/FSI/FAR etc shall be subject to verification and letter of PMRDA's competent Authority.



  
The Principal  
Indo Scots Global School, Pune.



  
MANAGER  
Indo Scots Global School  
Wagholi, Pune.


3. The required Marginal Open spaces as per DCPR requirements should be kept open and obstruction free at all time.

Please ensure that the system provided for the protection of the Education building should be maintained properly & regularly and certificate issued from the licensed agency should be submitted in the letter to this office on January & June every year.

This letter is issued considering the request of **M/s. Indoscots Foundation School**, for submission to the CBSE, Board Authorities Only.


Thanking you



Yours faithfully,  
  
(Devendra Potphode)  
Chief Fire Officer,  
PMRDA, PUNE



  
**MANAGER**  
Indo Scots Global School  
Wagholi, Pune.

  
The Principal  
Indo Scots Global School, Pune.

  
MANAGER  
Indo Scots Global School  
Wagholi, Pune



  
The Principal  
Indo Scots Global School, Pune





## MANOJ FIRE SERVICES

7B SUYASH TERRACE , KONDHWA KHURD, KONDHWA PUNE 411048  
Tele: 9890637101/9960848888

### FIRE SAFETY & SECURITY ENGINEERS

TO,  
INDO SCOTS GLOBAL SCHOOL  
Plot no, 1218, Baif Rd, next to Kancha Puram Society,  
Savannah, Wagholi, Pune

DATE: 5-Aug-24

#### SUB: SERVICE REPORT OF Pumps & Engine

S.R.N O	Details Of Equipments /Pumps	Location	Operation Mode	STATUS		REMARK
				START	STOP	
1	<b>MAIN PUMP</b> Make - Bharat Bijilee Sr. No. L1902874	GROUND	MANUAL	--	--	OK
2	<b>STANDBY PUMP</b> Make - Bharat Bijilee Sr. No. L1904379	GROUND	MANUAL	--	--	OK
3	<b>Booster Pump</b> Make - KIRLOSKAR Sr. No. A4A0CIC00381	Terrace	MANUAL	--	--	REPAIR
4	<b>JOCKEY Pump</b> Make - KIRLOSKAR Sr. No. 10220181268	GROUND	MANUAL	--	--	OK

MANOJ FIRE SERVICES



Authorised Signatory

The Principal  
Indo Scots Global School, Pune.



MANAGER  
Indo Scots Global School  
Wagholi, Pune.



# MANOJ FIRE SERVICES

7B Suyash Terrace, kondhwa Khurd, Kondhwa Pune 411048  
 9890637101/9960848888  
 FIRE SAFETY & SECURITY ENGINEERS  
 Website: www.manojfire.com

To, INDO SCOTS GLOBAL SCHOOL  
 Plot no, 1218, Baif Rd, next to Kancha Puram Society, Savannah, Wagholi, Pune  
 Date -5/8/2024

## SUB : QUARTERLY SERVICE REPORT OF FIRE HYDRANTS POINTS

Sr. NO	Level/ Location	Type of Point	Hose Box	Hose Cond	Small Glass	Big Glass	Key	Blank Cap	port Rubber Washer	Branch Pipe	HV Wheel	Lug Assmely	Port Hv Mouth	Hose Reel			Rub/ cap For 2/4 way	Remark
														Drum	Pipe	JSN		
1	7TH FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
2	7TH FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
3	6th FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
4	6th FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
5	5th FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
6	5th FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
7	4TH FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
8	4TH FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
9	3RD FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	NA	OK	OK	OK	OK		
10	3RD FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
11	2ND FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
12	2ND FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK		
13	1ST FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	4 WAY OK	
14	1ST FLOOR	SHV	OK	OK	OK	OK	OK	NA	OK	OK	OK	OK	OK	OK	OK	OK		
15	GRD FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK		
16	GRD FLOOR	SHV	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK		
17	GRD FLOOR-1	SHV	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK		
Sr.	Type of Point	Hose Box	Hose Cond	Small Glass	Big Glass	Key	Blank Cap	port Rubber Washer	Branch Pipe	HV Wheel	Lug Assmely	Port Hv Mouth	Hose Reel			Rub/ cap For 2/4 way	Remark	



MANAGEH...  
 Indo Scots Global School  
 Wagholi, Pune

The Principal





REF NO: MFEPL/FORMB

Fire Noc No : FFH/159/2023-24 Date: 26/09/2023

## FORM B

### CERTIFICATE

[(sec.section 3 (3) and rule 4 (2))]

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety measures Installed in the Following Building or Premises, namely\*:-

**M/s INDO SCOTS GLOBAL SCHOOL**

**GAT NO 1211+1213+TO 1216+1218**

**VILLAGE WAGHOLI, TAL HAVELI PUNE**

I/We further certify that these installations in the above mentioned Buildings are maintained in good repair and efficient conditions during The period **January 2024 TO June 2024** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah.III of 2007).The details of the inspection of installation carried Out by us are mentioned in the report appended here with.

Scope of Work - Fire Extinguisher and Fire Hydrant

SHAILESH  
ABASAHEB  
KUDALE



Place: PUNE



DATE: 07/08/2024

License No - MFS - LA/ RF-616/ RD-585

  
SIGNATURE.....

**The Principal**  
**Indo Scots Global School, Pune.**

  
MANAGER  
**Indo Scots Global School**  
**Wagholi, Pune.**

**Manoj Fire Protection LLP**

# MANOJ FIRE PROTECTION LLP

7-B, Suyash Terrace, Kondhwa Khurd, Kondhwa, Pune 411 048

## ANNEXURE

### INDO SCOTS GLOBAL SCHOOL

GAT NO 1211+1213+TO 1216+1218 VILLAGE WAGHOLI, TAL HAVELI PUNE

Sr. No.	System Description	QTY	Unit	Remarks
<b>A Hydrant System Description</b>				
1	No of fire Hydrant post	23	Nos	OK
2	No of fire Hose boxes	23	Nos	OK
3	No of fire Hose reel	16	Nos	OK
4	No of fire Hoses 2.5"	46	Nos	OK
5	No of Fire Nozzles	23	Nos	OK
6	Jockey Pump (Make Kirloskar - 10 HP)	1	Nos	OK
7	Main Pump (Hydrant) (Make BHARAT BIJALEE )	1	Nos	OK
8	Main Pump (Standby) (Make BHARAT BIJALEE)	1	Nos	OK
9	Booster Pump (Make Kirloskar 5 HP)	1	Nos	OK
10	No of Fire Bucket	4	Nos	OK
<b>B Fire Extinguishers</b>				
1	Fire Extinguisher ABC Type 6kg	8	Nos	OK
<b>C Fire Alarm System Description</b>				
1	No of Fire MCP	4	Nos	OK
2	Main Panel	1	Nos	OK
3	No of Hooters	4	Nos	OK

The above equipment has been tested and is found in good working condition also demonstrated to be concerned owner to his satisfaction.

SHAILESH  
ABASAHEB  
KUDALE



For Manoj Fire Protection LLP

(Authorised Signatory)

  
MANAGER  
Indo Scots Global School  
Wagholi, Pune.



  
The Principal  
Indo Scots Global School, Pune.



Govt. of Maharashtra  
 Directorate of Maharashtra Fire Service  
 Vidyasagar, Hans Bhugra Marg, Santacruz (East),  
 Mumbai - 400 098. Tel-022-26677555. Fax-022-26677666  
 www.mahafireservice.gov.in

**FORM N**  
 [ ( See section 9 (3) and rule 14 ) ]  
**License to act as a License Agency for the purpose of  
 Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-616 / RD- 585

Date: 16.12.2023

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Manoj Fire Protection LLP** (earlier known as **M/s. Manoj Fire Equipment Pvt Ltd.**) having their registered office at Office No. 401 & 402, Blueberry Biz, DY Patil Rd, Rawat-412101 and their contact details are Office Number: 9579993322 and Email ID: shailesh@manojgroup.com with PAN registration No. AAGCM6812P and GST No. 27AAGCM6812P1ZX to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class A
2. Detection and Fire Suppression System: Class A

**M/s. Manoj Fire Protection LLP** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **16.12.2023 to 15.12.2025**

Hatyal  
 Kiran  
 Asst Director

Digitally signed by Hatyal Kiran  
 Date: 2023.12.19  
 21:01:29 +05'30'

SHAILESH  
 ABASAHEB  
 KUDALE



Santosh  
 Shridhar  
 Warick


Digitally signed by Santosh Shridhar Warick  
 Date: 2023.12.19  
 22:15:12 +05'30'

( S S Warick )  
 Director  
 Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

\* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



**The Principal**  
 Indo Scots Global School, Pune.



**MANAGER**  
 Indo Scots Global School,  
 Wagholi, Pune.

