

NATIONAL ACCREDITATION BOARD FOR TESTING AND CALIBRATION LABORATORIES (NABL) WATER TESTING REPORT.

TESTING LABORATORY FOR :
FOOD | DRINKING WATER
STP WATER | ETP WATER

8623961555 | 020 27690555
info@biosourcebiotech.com
www.biosourcebiotech.com



Plot no 16, Gat no 87,
Jyotibanagar, Talwade Pune 411062

Test Report

Name of Customer : Indo Scot Global School
Address of the Customer : Plot No. 31218, Near Kanchapuram, Society, Baif Road, Wagholi, Pune-412207
Date of sample Receipt : 25/09/2024 Report Issue Date : 26/09/2024
Sample Code : BSB/2632/W/MBCH/24 ULR No. : TC125952400001908F
Name of Sample : Drinking Water Condition of Sample : Sealed (4^oc)
Quantity of Sample received : 1 Liter Sample Collected By : Mr. Vyankatesh Paatil
Discipline : Chemical & Biological Group : Water
Analysis start Date : 25/09/2024 Analysis end date : 26/09/2024
Testing Carried out at : Permanent facility Sample Collection Time : 4.05 pm

Result Table

| Sr. No. | Parameters tested | Observed Value | IS 10500: 2012 Required Standard | Unit | Reference Methods |
|----------------------------------|-------------------------------------|----------------|----------------------------------|---------|-------------------------|
| Physical Parameters | | | | | |
| 1 | Colour | 1 | Max. 5 | Hazen | IS 3025 (Part-4): 1983 |
| 2 | Odour | Agreeable | Agreeable | -- | IS 3025 (Part-5): 2018 |
| 3 | pH at 25 ^o C | 6.64 | 6.5-8.5 | -- | IS 3025 (Part-11): 1983 |
| 4 | Turbidity | 0.1 | Max. 1.0 | NTU | IS 3025 (Part-10): 1984 |
| 5 | Total Dissolved Solids | 84 | Max. 500 | mg/lit | IS 3025 (Part-16): 1984 |
| Chemical Parameters | | | | | |
| 6 | Alkalinity as CaCO ₃ | 28.36 | Max. 200 | mg/lit | IS 3025 (Part-23): 1986 |
| 7 | Total Hardness as CaCO ₃ | 12.36 | Max. 200 | mg/lit | IS 3025 (Part-21): 2009 |
| 8 | Calcium as Ca | 3.29 | Max. 75 | mg/lit | IS 3025 (Part-40): 1991 |
| 9 | Magnesium as Mg | 1.00 | Max. 30 | mg/lit | IS 3025 (Part-46): 1994 |
| 10 | Chlorides as Cl | 24.60 | Max. 250 | mg/lit | IS 3025 (Part-32): 1988 |
| Microbiological Parametrs | | | | | |
| 11 | E.coli | Absent | Absent | /100 ml | IS 15185: 2016 |
| 12 | Coliform | Absent | Absent | /100 ml | IS 15185: 2016 |

Opinion: The collected water sample is within the prescribed limit of Drinking Water Specification IS 10500: 2012 for Above parameters.

-----End of Report -----

Verified & Authorized by
(Biological)

Mr. Vyankatesh Paatil


Note: 1. The above results pertain only to the sample tested & without prejudice of source/process

2. Any correction to this report invalidates the report.

3. This report can not be used for court purpose. We are not responsible for any legal matter.

Issue Date : 01/10/2019 Revision No. 04 Format No. BSB/REC/7.8/021

The Principal
Indo Scots Global School, Pune.



Verified & Authorized by
(Chemical)
Mrs. Vijaya Kasalkar



MANAGER
Indo Scots Global School
Wagholi, Pune.

SAFE SANITARY CONDITION CERTIFICATE

No.

Dated:

20/7/24,

It is certified that an inspection team headed by P. H. C. Waghole

(Name of Officers with designation) from

Department/Office) inspected the INDO SCOTS GLOBAL SCHOOL, WAGHOLI

(Name & Address of the school) on 20/7/24 (date of inspection) and found that the

School INDO SCOTS GLOBAL SCHOOL, WAGHOLI maintains the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for a period of 20/7/24 to 19/7/25

The above certificate is issued to Indo Scots Global School, Pune on their request for the CBSE affiliation

Signature with Seal:

Name :

Designation :

[Handwritten Signature]

वैद्यकीय अधिकारी
राष्ट्रीय आरोग्य केंद्र वाघोली
ता. हवेली, जि. पुणे

To, THE PRINCIPAL

INDO SCOTS GLOBAL

SCHOOL, PUNE

[Handwritten Signature]

The Principal
Indo Scots Global School, Pune.



वैद्यकीय अधिकारी
राष्ट्रीय आरोग्य केंद्र वाघोली
ता. हवेली, जि. पुणे.

[Handwritten Signature]

MANAGER
Indo Scots Global School
Wagholi, Pune.